ADMINISTRATION

50 NELLIS DRIVE

KEY:	**TNR: TESTING NOT REQUIRED**		
	DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION		
	ND: None Detected BS: Below DEP / EPA Standard		
			Test Date 4/5/16 & 2/17/2017
SAMPLE NUMBER	**SAMPLE DESCRIPTION / LOCATION**	**FIRST DRAW TEST RESULTS**	**REMEDIAL ACTION NOTES**
L6687082-1	WORKSHOP FACET	< 1.0	BS
L6687082-2	TECH DEPARTMENT FOUNTAIN	3.2	BS
L6687082-3	MAIN OFFICE FOUNTAIN	< 1.0	BS
L6173312-1	FOUNTAIN 1st FLOOR	<15 ppb	BS
L6173312-2	UPPER OFFICE KITCHEN SINK	ND	ND/BS
L6173312-3	SHOP FOUNTAIN	<15 ppb	BS
L6173312-4	FOUNTAIN BY PARKING LOT MAIN FLOOR	<15 ppb	BS