	TRANSPORTATION BUS GARAGE	
	195 DEY ROAD	
KEY:	TNR: TESTING NOT REQUIRED	
	DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILL	
	ND: None Detected BS: Below DEP / EPA Standard	
SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS
L6444471-1	OFFICES/GARAGE UTILITY SINK	< 0.500
L6444471-2	OFFICE BATHROOM SINK	< 0.500
L6444471-3	MENS ROOM SINK LEFT	0.770
L6444471-4	MENS ROOM SINK RIGHT	< 0.500
L6444471-5	WOMENS ROOM SINK	< 0.500
L6444471-6	BREAKROOM SINK	< 0.500
L6444471-7	BREAKROOM FAUCET WITH FILTERS	< 0.500

ION

Test Date 12/8/2016

REMEDIAL ACTION NOTES
BS
BS
BS
BS
BS
BS
BS